

March 19, 2026

Addendum No. 3

Chase Avenue Pump Station Upgrades Project

Answers to Contractor Questions - Clarification:

Delete the answer to Question 3 in Addendum #2 and replace with the answer below:

3. Q. Would it be acceptable to use one of the old pumps and one of the new pumps for temporary bypass pumping?
 - A. A plan to use one existing pump in the pump station and one of the new replacement pumps for bypass pumping would be considered, however the pump manufacturer & supplier must explicitly support this approach, and it must have no adverse impact on the warranty. The warranty period for the new pumps shall begin when the pump station is placed online at substantial completion. The Contractor is responsible for maintaining continued operation of the bypass pumping. Except for shutdowns of less than 24 hours which must be coordinated with the Owner, the Contractor shall always maintain a duty and a stand-by bypass pump.

End of Addendum No. 3

Please reply to angela@dirigoeng.com to confirm you have received Addendum #3